

A Review on Optimal Sizing, Stability Control and Energy Management Techniques for PV and Wind (Hybrid) AC/DC Microgrids

Reena Upadhyay¹, Pramod Kumar Rathore²

¹Student, ²Assistant Professor,

^{1,2}RKDF College of Engineering, Bhopal, Madhya Pradesh, India

ABSTRACT

Electricity is humanity's biggest technological gift, because it is used for all. However, in recent years, there has been a paradigm change in the production of electrical electricity from the idea of utilizing large generating plants to minor generating units linked to distribution networks in the form of microgrids using renewable energy sources. Renewable energy usage is increasing across the world, and these alternative energy sources will provide pollution-free electrical energy for the community. Despite the fact that there are modern centers and units with decreasing costs, operating and controlling islanded and grid-connected microgrids designed in both AC and DC poses several challenges. Hybrid AC-DC Microgrids (HACDC) were created by combining the advantages of AC and DC microgrids. As a result, it is comparatively critical to investigate the optimum scale, stability regulation, and economic quality operating strategies of the HACDC microgrid. As a result, this paper provided a comprehensive analysis of optimum sizing approaches, stability regulation, and energy conservation solutions utilizing various iterative and information techniques published in various papers suggested by numerous authors.

KEYWORDS: Solar, Wind, Hybrid, AC/DC Microgrid, Stability Control, Inter-Allied Converter, Energy Management System

INTRODUCTION

Recently From the survey, it has been identified that an average Indian consumes 1075kwh of electricity annually, and 85% of electricity is generated from fossil fuels as principal resources of energy, which causes large amount of CO₂ emissions to lead to global warming. But due to the growth of demand for electric power, the inadequate reserve and lifting worth of conservative sources such as firewood and petroleum, etc. renewable energy sources become a gifted substitute, available free of cost, atmosphere friendly and has a reduced amount of operational and maintenance cost. The higher penetration of various technologies of renewable energy sources such as solar, wind, tidal, biomass, and geothermal forms a distribution generation (DG). The vast scale incorporation of DG's will bring operational confronts to the power system network, and a vital solution to this predicament is a microgrid achieved much concentration globally [1]. At present, due to generation of electrical energy in both (AC and DC) forms with the use of various renewables; microgrids are classified as AC Microgrids, DC Microgrids, and HACDC Microgrids [2]. In AC

microgrids, the DC generating sources such as PV, Fuel Cells are converted to AC with the use of DC/AC converters, while AC generating sources are directly allied using power electronic interfaces [3]. Whereas, in case of DC microgrids AC generating sources are converted to DC using AC/DC converters. However, these multiple conversions results in losses. An immediate solution to the problems mentioned above is hybrid microgrid, which minimizes multiple conversions and reduction in losses [4]. The two notable and key aspects bracketed together concerning hybrid systems are worth of electrical power and consistency of the system. The systems' best possible blueprint must be cost-effective and consistent, and it can be accomplished with the rally round of appropriate choice of apparatus of the system. Thus, an optimal sizing method is obligatory to propose a proficient and costeffective HACDC microgrid system. The structure of hybrid microgrid consisting of renewables Photo-Voltaic (PV), Wind Turbine (WT) with Battery Energy Storage, and loads allied to utility grid is shown in Fig 1.

How to cite this paper: Reena Upadhyay | Pramod Kumar Rathore "A Review on Optimal Sizing, Stability Control and Energy Management Techniques for PV and Wind (Hybrid) AC/DC Microgrids" Published in International Journal of Trend in Scientific Research and Development (ijtsrd), ISSN: 2456-6470, Volume-5 | Issue-4, June 2021, pp.709-715,

URL: www.ijtsrd.com/papers/ijtsrd42404.pdf

Copyright © 2021 by author (s) and International Journal of Trend in Scientific Research and Development Journal. This is an Open Access article distributed under the terms of the Creative Commons Attribution License (CC BY 4.0) (<http://creativecommons.org/licenses/by/4.0>)



IJTSRD42404






Figure.1 Layout of HACDC Microgrid

From Fig.1, the HACDC microgrid is allied to the service grid through an isolator switch [5], which helps to isolate the HACDC microgrid during faulty times. Under steady-state conditions, the HACDC microgrid can be functioned in two modes, such as grid allied mode and island mode. Maintenance of power balance between hybrid and utility grid is moderately easy in grid-connected mode [6] as compared to islanded mode because of infinite bus behaviour of utility grid [7] and be able to absorb or supply to the HACDC microgrid. In the case of islanded mode, the HACDC microgrid is no longer allied to the utility grid. Hence, the HACDC itself must supply the total load demand through Inter-Allied Converter (IAC). Therefore, a communication link is allied among the sources. A centralized method of control is applied between the sources, but it is a single point failure. A commonly known method called droop method, used for sensing of load demand by each source and regulates its production according to its rated capacity [8]. During transition from grid allied mode to islanded mode or vice-versa, unstable harmonic currents and voltages are of crucial concern. In addition to this, proper synchronization of voltage and phase between HACDC microgrid and utility grid is necessary. To increase the generation and to meet the load demand, renewable sources, together with storage devices, are integrated into the utility grid, causing challenges and impacts on microgrid operation. The organization of paper is as follows. A rigorous literature review on different methods of optimal sizing of HACDC microgrid is presented in section II, followed by stability control strategies in section III, and section IV presents energy management strategies for HACDC microgrids. Finally, the conclusion of the review is presented in section V.

OPTIMAL SIZING METHODS:

Nowadays, a paradigm shift for exploit of HACDC microgrids due to radical transformations like load due to the advancement in electronically based distribution generation. The vital aspect of HACDC microgrids is the high operational cost of renewables and the large size of Battery Energy Storage Systems (BESS). For optimization of capacities of Photo Voltaic (PV), Wind Turbines (WT), and BESS, various iterative and intelligent methods were developed and discussed briefly. In [9], to congregate the load demand and for minimization of total annual cost, hybrid systems generation and storage units are sized by a numerical study based on hourly load demand. By considering economic factors, a simple arithmetical algorithm was built up to gratify the available load demand and to determine the optimal configuration of WT/PV. In [10], the optimal design

of hybrid microgrid system is obtained by employing linear programming methods for minimization of the annual price of generation while meeting the prerequisites of load in a consistent approach. Environmental factors are also considered in both design and operation phases. In addition to the determination of annual cost, balanced generation, and demand by a simple numerical algorithm, an economic analysis is also presented to justify the use of renewable energy. Comparison by configuration cost and break-even distance is also made among the solar alone, wind alone, and hybrid systems [11]. Different components of hybrid solar-wind system with the existence of battery banks are sized optimally to minimize the capacity by using Loss of Power Supply Probability (LPSP) approach to level the cost of energy [12]. The system configuration is obtained in terms of power supply reliability. The crucial aspects considered in the optimization problem are cost, reliability and pollutant emissions. In [3], a technique was proposed called multi-objective Particle Swarm Optimization (PSO) to obtain the optimal configuration of the grid-connected hybrid system using multiple renewable energy sources. [14] determined the optimal sizing of PV/WT grid-connected system among different configurations using multi-criteria decision analysis. The sensitivity of these algorithms is also analysed with various techniques of weighting criteria in different scenarios like wind speed and radiation profiles of solar. An improved optimal sizing method for a hybrid generating system consisting of PV/WT and battery was proposed in [15], by considering the principles such as high reliability of power supply, characteristics of utilization of PV/WT, battery charge and discharge state optimization and finally system's total cost minimization. According to [16], the characteristics of load changes using various renewable generation sources because of their different geographic regions during a year. Due to this reason, collective capacity optimization is proposed for the reduction in generation cost and storage by considering investment and operational cost. [17] proposed an optimization framework to assess the capacity of distributed generation and focus on maximum profit with utilization of renewables, minimization of pollution in the environment, and the increase in reliability level, forming a master objective function. The optimal design can be determined using PSO algorithms. With the consideration of the integration of renewables, the stage of design can be complicated. In [18], the optimal model can be designed based on mixed-integer linear programming, which includes the stochastic behaviour of renewables and uncertainty in the prediction of electric load. In [19], optimal sizing of hybrid PV/WT and battery systems is based on two constraint search algorithms and aimed at avoiding of over and under sizing. This paper also considered the forced outage rates of solar, wind and utilization factor of battery energy storage systems to make the design more realistic. [20] determined the energy sources unit location and optimal power of a hybrid AC/DC system by formulating as a mixed-integer linear programming and solved by using CPLEX optimization studio includes total cost minimization. The proposed work in [21] determines not only the optimal configuration of renewable sources but also the power electronic converters needed in the hybrid microgrid. The effectiveness of the proposed work can be obtained by using "deterministic branch-and-bound non-linear solver."

VOLTAGE AND FREQUENCY CONTROL METHODS:

Various control approaches were implemented for both AC and DC microgrids individually [22] to uphold the voltage

and frequency in synchronous with utility grid during fault conditions. The same control strategies were implemented to HACDC microgrid also, but a little attention has received towards HACDC microgrid because of Inter-Allied converter (IAC) present in the HACDC microgrid. By considering the significance of hybrid microgrid, the paper presents a synopsis of different control approaches of Interlinking Converter (IC) based on droop or communication control methods [23], [24] for voltage and frequency control of hybrid microgrid in standalone and transition mode. But the most dynamic control can be acquired by exploiting amalgamation of these two control methods. The aspiration is to comprehend the functionality of projected schemes. So that better control approaches may be enlarged for the future grid.




Figure.2 An outline of different control methods of voltage and frequency of IAC in HACDC Microgrid

The first step of controlling voltage and frequency in a HACDC microgrid is to manage the flow of power within the grid separately then secondly, IAC comes into play to supervise the power flow from under loaded grid to the overloaded grid. An outline of various control methods of voltage and frequency for IAC in detached mode is depicted in Fig.2.

DECENTRALIZED OR DROOP BASED CONTROL METHODS:

Before reviewing the essential aspects of decentralized control methods for IAC of HACDC microgrid, some of the conventional droop control methods for each microgrid are explained. The various conventional droop methods are DC droop control, Angle droops control method, a voltage and current droop control. Generally, methods of droop control are used to determine the voltage V and frequency f of HACDC microgrids and are given by the (1) and (2)

$$f_y = f_x + m_x P_x \quad (1)$$

$$V_y = V_x + n_x Q_x \quad (2)$$

Where V_x, f_x are no-load upper limit values of voltage and frequency, m_x, n_x are negative droop coefficients.

DROOP CONTROL METHOD OF ANGLE:

In the Angle droop method, the real and reactive power flow is controlled using the voltage angle. Its droop characteristics can be set by the ratings of Distribution Generation (DG), and for each converter, a reference time

signal is used for synchronization based on Global Positioning System (GPS) [27]. The existence of any mismatch in the system tends to system instability. For the regulation of voltage, voltage current droop is implemented only in DC grids. Where the converter DC current through the virtual resistance is measured and applied at the input to give output voltage as DC. The DC output voltage is controlled by designing a proportional controller with gain equal to virtual resistance, and this proposal has a drawback of deviation in load voltage. The minimization of these deviations can be done using a controller called the Proportional plus Integral (PI) controller [28].

DROOP CONTROL METHOD OF VOLTAGE AND CURRENT:

In [29], the voltage and frequency droop control methods were proposed for microgrid operating in unconnected mode or connected to an infinite bus. A comparison is made between the existing techniques and concluded that droop control of microgrid through the finite output impedance method exhibits superior behaviour in the reduction of harmonics. A strategy of control and sharing of power was anticipated by [30] consisting of virtual inductance at the output of interfaced inverter for accurate control of real and reactive power in both allied and unconnected mode with no physical communication among the units of DG. According to [31], a hierarchical method of control was proposed for both AC and DC microgrids consisting of three levels. The primary control is based on the droop method including virtual loop of output impedance, the secondary control loop restores the variations produced by primary control, and tertiary control loop manages the power flow between the microgrid and the external electrical distribution systems. Even though the conventional droop control methods achieve a higher reliability level, this method faces a disadvantage of slow transient response, deviation in voltage, sharing of unbalanced harmonic current, and highly dependent on the output impedance of inverter. To conquer the above drawbacks, modified method of droop control was proposed in [32] to enhance the dynamic performance.

INTER ALLIED CONVERTER DROOP CONTROL METHODS:

After the implementation of droop methods individually to each microgrid, the subsequent task is to manage the flow of power among sub grids for the regulation of voltage and frequency. This can be achieved using IAC, but due to continuous operation of IAC, loss in energy occurs. To minimize these energy losses, IAC is designed based on power flow of energy storage tuning between the sub grids of AC and DC [33]. This scheme utilizes a stationary reference frame with multiple PI controllers for generation pulse width modulation. For the determination of loading inside each grid, the measurement of DC grid voltage and AC grid frequency is required. Hence, a modified method of the ac-dc droop control scheme is presented in [34]. This method has a direct impact on AC sub grid frequency; hence multiple IACs can be used. A double loop control scheme shown in Fig.3 [35] involving three-level controls is used for the regulation of voltage and frequency, which increases system cost, complexity, and accurate tuning of PI controller is also required.




Figure. 3 Double loop control schemes with proper tuning of PI Controller

For the cost-effective operation of the system, another method called voltage-current droop control method is implemented using a proportional resonant controller, including a PI controller. In this scheme, the value of virtual resistance should be appropriately selected when working with parallel converters.

CONTROL BASED ON COMMUNICATION:

As the name itself says that, this method of control is based on continuous information exchange among the variety of microgrid resources. In this approach, microgrid control can be centralized or fully distributed with high accuracy because of less communication delay during information exchange [36]. But if there exists a loss of communication link security and reliability issues raises affecting system stability. To overcome the problem of stability and reliability issues, a hierarchical control scheme is proposed with a combination of droop and communication methods. The underlying implementation of centralized control for HACDC microgrid is shown in Fig.4.




Figure.4 General Structure of Centralized control of HACDC microgrid

In this configuration, AC and DC sub grids are allied utilizing a bidirectional inter-allied converter with one centralized controller. In centralized communication-based control, all the data from local distributed energy resources controllers are transmitted to the microgrid central controller in real-time. Hence this approach is a single point failure but has better response compared to droop control. Using power regulators, a control strategy based on communication is applied [37] at each source in the microgrid. For synchronization of phase and frequency, including reference signal, current modules with phased lock loop (PLL) are proposed in [38]. A simple and effective approach named master-slave control was described by [39], which can be

applied in both grid connection mode and island mode. In this method of control, one converter works as a master and other works as a slave for the existence of data transmission between master and slave controllers. Even though this method is not much complicated from technical point of view, but the failure of the master controller affects the total system operation, and its reliability also decreased. To avoid communication links and to provide good capability of expansion, an alternate method of control was proposed in [40] called peer to peer control. In this scheme, the existence of oscillations in power and decrease in energy usage occurs with increment in renewable energy sources number. Generally, master-slave approach is employed in island mode of operation, whereas peer to peer method is applicable in the grid allied mode of operation. So, there exists a problem of stability in switching. To resolve this problem, a hierarchical method is developed in [41] and suitable for sophisticated microgrids. Overcoming the single point failure with centralized control, an alternate form of control based on communication is designed without a central controller called distributed control. In this control mechanism, a control action is designed at the local converters within the microgrid. The operational information of each source is communicated with neighbour ones, and the concluded information is gathered at the IAC. In this process, the information is communicated to the IAC which produces the necessary control actions to control voltage and frequency. This method can be implemented both in grid allied and island mode. Loss of any unit may cause system instability [42]. In [43], a Supervisory Control and Data Acquisition (SCADA) were proposed to supervise and control the devices or equipment present in microgrid based on the technology of the computer. For reliable control and communication of microgrid [44] proposed a device called Phasor measurement Unit (PMU), a microprocessor-based intelligent device that gathers data with high resolution and records disturbances. Even though SCADA and PMUs provide timely and detailed monitoring of microgrid, it contains some hidden information. The engineer requires additional analysis, and it is a time-consuming process. To overcome such limitations, Multi-Agent Systems (MAS) were replaced for the autonomous operation of microgrids with high intelligence to improve the reliability of voltage and frequency. MAS can be implemented using different frame works such as JADE, JANUS, ZEUS, and VOLTRON. Comparing the various properties of MAS, the suitable frame work for implementation of MAS is JADE. In [45] a multi-agent control has developed to enhance the voltage and to increase the speed and accuracy in decision making.

ENERGY MANAGEMENT STRATEGIES:

Presence of more than two distribution energy resources (DERs) in the system, the existence of Energy Management System (EMS) is necessary for the allocation of power among DERs, the production cost of energy, and emission. According to International Electro-technical Commission (IEC) standard 61970 EMS is defined as "a computer system comprising a software platform providing basic support services and a set of applications providing the functionality needed for the effective operation of electrical generation and transmission facilities to assure adequate security of energy supply at minimum cost." The various categories of energy management strategies were depicted in Fig.5.




Figure.5 Energy Management Strategies

To predict hourly outputs in a high-frequency AC microgrid, an intelligent energy management system called fuzzy ARTMAP neural network was proposed in [46] using adaptive resonance theory. Based on developed rules, an energy management strategy named as Rule-Based Method was proposed by [47] for stand-alone Wind-PV-Fuel Cell system. In [48], an expert and predictive system using mix integer linear programming method were proposed for optimal energy management. A real-time EMS using particle swarm optimization (PSO) technique was developed by [49] to minimize the operating cost. To balance the power among the sources, power control and management strategy was implemented by [50] in simulation PSCAD/EMTDC software. For effective energy management of HACDC microgrids, a two-stage method called crow search method was proposed in [51] to increase the search ability.

CONCLUSIONS:

An effort is made to depict the material provided in the literature by various writers. This paper provides information on the existing state of HACDC microgrids, as well as the role of renewables and the problems associated with the production of electrical energy in the developing world. This paper presents numerous optimum sizing approaches, stability regulation techniques, and energy conservation tactics applied in both island and grid allied modes of HACDC microgrids, together with their advantages and drawbacks, to enlighten researchers in the field of HACDC microgrids. Various optimization techniques, including iterative approaches, intelligent methods, and software technologies, are also proposed for optimum function of the HACDC microgrid. A extensive literature review on different control techniques, ranging from well-known droop methods to contact methods such as unified and dispersed, is also presented. The paper also reviews numerous energy management techniques of the HACDC microgrid proposed in the literature in order to provide proper energy delivery among various sources in the island mode of activity and to obtain a controlled flow of power between the utility grid and the HACDC microgrid in a grid allied mode. Furthermore, this paper enables the researcher to easily grasp the current situation in the field of HACDC microgrid overall output in both islanded and grid-connected modes.

REFERENCES

[1] Hina Fathima Prabakaran N Palanisamy K Akhtar Kalam Saad Mekhilef Jackson Justo: A text book

on 'Hybrid Renewable Energy Systems in Microgrids', Woodhead publishing, 1st Edition 5th June 2018

- [2] Justo, Jackson John, et al. "AC-microgrids versus DC-microgrids with distributed energy resources: A review." *Renewable and Sustainable Energy Reviews* 24 (2013): 387-405
- [3] Lidula, N. W. A., and A. D. Rajapakse. "Microgrids research: A review of experimental microgrids and test systems." *Renewable and Sustainable Energy Reviews* 15. 1 (2011): 186-202.
- [4] Planas, Estefanía, et al. "AC and DC technology in microgrids: A review." *Renewable and Sustainable Energy Reviews* 43 (2015): 726-749.
- [5] Loh, Poh Chiang, et al. "Autonomous operation of hybrid microgrid with AC and DC subgrids." *IEEE transactions on power electronics* 28. 5 (2012): 2214-2223.
- [6] Nejabatkhah, Farzam, and Yun Wei Li. "Overview of power management strategies of hybrid AC/DC microgrid." *IEEE Transactions on Power Electronics* 30. 12 (2014): 7072-7089.
- [7] Majumder, Ritwik, et al. "Improvement of stability and load sharing in an autonomous microgrid using supplementary droop control loop." *IEEE transactions on power systems* 25. 2 (2009): 796-808.
- [8] Mohamed, Yasser Abdel-Rady Ibrahim, and Ehab F. El-Saadany. "Adaptive decentralized droop controller to preserve power sharing stability of paralleled inverters in distributed generation microgrids." *IEEE Transactions on Power Electronics* 23. 6 (2008): 2806-2816.
- [9] Kellogg, W., Nehrir, M., Venkataramanan, G., et al. : 'Optimal unit sizing for a hybrid wind/photovoltaic generating system', *Electr. Power Syst. Res.*, 1996, 39, (1), pp. 35-38.
- [10] Chedid, Riad, and Saifur Rahman. "Unit sizing and control of hybrid wind-solar power systems." *IEEE Transactions on energy conversion* 12. 1 (1997): 79-85.
- [11] Kellogg, W. D., et al. "Generation unit sizing and cost analysis for stand-alone wind, photovoltaic, and hybrid wind/PV systems." *IEEE Transactions on energy conversion* 13. 1 (1998): 70-75.
- [12] Yang, Hongxing, Lin Lu, and Wei Zhou. "A novel optimization sizing model for hybrid solar-wind power generation system." *Solar energy* 81. 1 (2007): 76-84.
- [13] Wang, Lingfeng, and Chanan Singh. "PSO-based multi-criteria optimum design of a grid-connected hybrid power system with multiple renewable sources of energy." *2007 IEEE Swarm Intelligence Symposium. IEEE*, 2007.
- [14] Alsayed, Mohammed, et al. "Multicriteria optimal sizing of photovoltaic-wind turbine grid connected systems." *IEEE Transactions on energy conversion* 28. 2 (2013): 370-379.
- [15] Xu, Lin, et al. "An improved optimal sizing method for wind-solar-battery hybrid power system." *IEEE*

- transactions on Sustainable Energy 4. 3 (2013): 774-785.
- [16] Yang, Peng, and AryeNehorai. "Joint optimization of hybrid energy storage and generation capacity with renewable energy." *IEEE Transactions on Smart Grid* 5. 4 (2014): 1566-1574.
- [17] Moradi, Mohammad H., Mohsen Eskandari, and S. Mahdi Hosseinian. "Operational strategy optimization in an optimal sized smart microgrid." *IEEE Transactions on Smart Grid* 6. 3 (2014): 1087-1095.
- [18] Atia, Raji, and Noboru Yamada. "Sizing and analysis of renewable energy and battery systems in residential microgrids." *IEEE Transactions on Smart Grid* 7. 3 (2016): 1204-1213.
- [19] Akram, Umer, Muhammad Khalid, and Saifullah Shafiq. "Optimal sizing of a wind/solar/battery hybrid grid- connected microgrid system." *IET Renewable Power Generation* 12. 1 (2017): 72-80.
- [20] Alanazi, Abdulaziz, Hossein Lotfi, and Amin Khodaei. "Optimal Energy Storage Sizing and Siting in Hybrid AC/DC Microgrids." *2018 North American Power Symposium (NAPS)*. IEEE, 2018.
- [21] A. A. Hamad, M. E. Nassar, E. F. El-Saadany and M. M. A. Salama, "Optimal Configuration of Isolated Hybrid AC/DC Microgrids," in *IEEE Transactions on Smart Grid*, vol. 10, no. 3, pp. 2789-2798, May 2019.
- [22] Nejabatkhah, Farzam, and Yun Wei Li. "Overview of power management strategies of hybrid AC/DC microgrid." *IEEE Transactions on Power Electronics* 30. 12 (2014): 7072-7089.
- [23] Eghtedarpour, Navid, and Ebrahim Farjah. "Power control and management in a hybrid AC/DC microgrid." *IEEE transactions on smart grid* 5. 3 (2014): 1494-1505.
- [24] Zhang, Junliu, et al. "Control strategy of interlinking converter in hybrid AC/DC microgrid." *"2013 International Conference on Renewable Energy Research and Applications (ICRERA)*. IEEE, 2013.
- [25] Karlsson, Per, and Jörgen Svensson. "DC bus voltage control for a distributed power system." *IEEE transactions on Power Electronics* 18. 6 (2003): 1405-1412.
- [26] Caldognetto, Tommaso, and Paolo Tenti. "Microgrids operation based on master-slave cooperative control." *IEEE Journal of Emerging and Selected Topics in Power Electronics* 2. 4 (2014): 1081-1088.
- [27] Sun, Qiuye, et al. "Hybrid three-phase/single-phase microgrid architecture with power management capabilities." *IEEE Transactions on Power Electronics* 30. 10 (2014): 5964-5977.
- [28] De Brabandere, Karel, et al. "A voltage and frequency droop control method for parallel inverters." *IEEE Transactions on power electronics* 22. 4 (2007): 1107- 1115.
- [29] Li, Yun Wei, and Ching-Nan Kao. "An accurate power control strategy for power-electronics-interfaced distributed generation units operating in a low-voltage multibus microgrid." *IEEE Transactions on Power Electronics* 24. 12 (2009): 2977-2988.
- [30] Guerrero, Josep M., et al. "Hierarchical control of droop- controlled AC and DC microgrids—A general approach toward standardization." *IEEE Transactions on industrial electronics* 58. 1 (2010): 158-172.
- [31] Kim, Jaehong, et al. "Mode adaptive droop control with virtual output impedances for an inverter-based flexible AC microgrid." *IEEE Transactions on power electronics* 26. 3 (2010): 689-701.
- [32] Loh, Poh Chiang, et al. "Hybrid AC–DC microgrids with energy storages and progressive energy flow tuning." *IEEE transactions on power electronics* 28. 4 (2012): 1533-1543.
- [33] Eghtedarpour, Navid, and Ebrahim Farjah. "Power control and management in a hybrid AC/DC microgrid." *IEEE transactions on smart grid* 5. 3 (2014): 1494-1505.
- [34] Zhang, Junliu, et al. "Control strategy of interlinking converter in hybrid AC/DC microgrid." *"2013 International Conference on Renewable Energy Research and Applications (ICRERA)*. IEEE, 2013.
- [35] Eid, Bilal M., et al. "Control methods and objectives for electronically coupled distributed energy resources in microgrids: A review." *IEEE systems journal* 10. 2 (2014): 446-458.
- [36] Han, Hua, et al. "Review of power sharing control strategies for islanding operation of AC microgrids." *IEEE Transactions on Smart Grid* 7. 1 (2015): 200-215.
- [37] Wei, Bao, et al. "An novel hierarchical control of microgrid composed of multi-droop controlled distributed power resources." *"2015 5th International Conference on Electric Utility Deregulation and Restructuring and Power Technologies (DRPT)*. IEEE, 2015.
- [38] Eid, Bilal M., et al. "Control methods and objectives for electronically coupled distributed energy resources in microgrids: A review." *IEEE systems journal* 10. 2 (2014): 446-458.
- [39] Caldognetto, Tommaso, and Paolo Tenti. "Microgrids operation based on master-slave cooperative control." *IEEE Journal of Emerging and Selected Topics in Power Electronics* 2. 4 (2014): 1081-1088.
- [40] Alfergani, Asma, and Ashraf Khalil. "Modeling and control of master-slave microgrid with communication delay." *"2017 8th International Renewable Energy Congress (IREC)*. IEEE, 2017.
- [41] Dou, Chunxia, et al. "Hierarchical hybrid control strategy for micro-grid switching stabilisation during operating mode conversion." *IET Generation, Transmission & Distribution* 10. 12 (2016): 2880-2890.
- [42] Loh, Poh Chiang, et al. "Autonomous control of interlinking converter with energy storage in hybrid AC– DC microgrid." *IEEE Transactions on Industry Applications* 49. 3 (2013): 1374-1382.

- [43] Chen, Y. N., and Wei Pei. "Design and implementation of SCADA system for Micro-grid. "Inf. Technol. J 12 (2013): 8049-8057.
- [44] Kumar, Shantanu, Narottam Das, and Syed Islam. "Performance monitoring of a PMU in a microgrid environment based on IEC 61850-90-5. "2016 Australasian Universities Power Engineering Conference (AUPEC). IEEE, 2016.
- [45] Khatibzadeh, Ahmadali, et al. "Multi-agent-based controller for voltage enhancement in AC/DC hybrid microgrid using energy storages. "Energies 10. 2 (2017): 169.
- [46] Chakraborty, Sudipta, Manoja D. Weiss, and M. Godoy Simoes. "Distributed intelligent energy management system for a single-phase high-frequency AC microgrid. "IEEE Transactions on Industrial electronics 54. 1 (2007): 97-109.
- [47] Wang, Caisheng, and M. Hashem Nehrir. "Power management of a stand-alone wind/photovoltaic/fuel cell energy system. "IEEE transactions on energy conversion 23. 3 (2008): 957-967.
- [48] Pham, TT Ha, Frédéric Wurtz, and Seddik Bacha. "Optimal operation of a PV based multi-source system and energy management for household application. "2009 IEEE International Conference on Industrial Technology. IEEE, 2009.
- [49] Pourmousavi, S. Ali, et al. "Real-time energy management of a stand-alone hybrid wind-microturbine energysystem using particle swarm optimization. "IEEE Transactions on Sustainable Energy 1. 3 (2010): 193-201.
- [50] Eghtedarpour, Navid, and Ebrahim Farjah. "Power control and management in a hybrid AC/DC microgrid. "IEEE transactions on smart grid 5. 3 (2014): 1494-1505.
- [51] Papari, Behnaz, et al. "Effective Energy Management of Hybrid AC-DC Microgrids with Storage Devices. "IEEE transactions on smart grid 10. 1 (2017): 193-203.

